



## Grid Integration of Wind Energy in the Western Cape – Results of Feasibility Studies

ESKOM/DIGSILENT/GTZ – 24.07.2009





### Grid Integration of Wind Energy in Western Cape: General Scope of Work



- Stage 1: Wind farm connection to a subtransmission grid
  - Identify potential issues and mitigation options
  - Example: Connection of 150MW wind farm at Laingsburg to 132kV grid
- Stage 2: Wind farm connection to the transmission grid
  - Identify potential issues and mitigation options
  - Example: Connection of 750MW of wind farms in Karoo area to the 400kV grid
- Stage 3: Study the impact of all wind farms in the Western Cape, for which applications exist (2796MW in total), on the existing ESKOM transmission system (400kV/765kV network).
  - High level feasibility studies for the integration of up to 2800MW of wind generation into the Western Cape.
  - Analyse the impact of wind generation on the transmission system

GTZ/ESKOM/DIGSILENT Presentation of results of feasibility studies for wind integration in the Western Cape

2



## Stage 1: Example for a Wind Farm Connection Study at Subtransmission Level



### Stage 1: 150MW Wind Farm near to Laingsburg – Scope of Studies

- Impact on thermal limits in the surrounding distribution network
  - Identification of possible Issues
  - Mitigation options
- Impact on voltage variations at the connection point and the surrounding distribution system:
  - Required reactive power control method (const power factor, voltage control, fast/slow voltage control, droop control....)
  - Required reactive range of wind farm for maintaining the voltage.
- Impact on short circuit levels
- Impact on Power Quality aspects (Harmonics/Flicker, IEC 61400-21)

GTZ/ESKOM/DIGSILENT Presentation of results of feasibility studies for wind integration in the Western Cape 4






## 150MW at Laingsburg – Impact on Thermal Limits



- Minor overload under n-1: 120% based on „normal ratings“.
- General mitigation options if thermal limits are exceeded:
  - Build a new line
  - Limit wind farm output to 120MW during all times (80% of rated output)
  - Limit wind farm output in case of actual line failure (manual or automatic inter-trip).
  - Consider dynamic line rating systems.



## Violation of Thermal Limits – Cap Wind Farm Output





## Violation of Thermal Limits – Mitigation Option 1



### Not Delivered Energy depends on:

- Wind conditions (average wind speed)
- Site-specific aspects
- Power curve of turbines

### Rough cost estimates:

- $v_w=7\text{m/s}$ :
  - Energy not delivered around 5% of potential energy
  - 150 MW wind-farm: 19 000MWh not delivered -> 23 750 000 R/year
- $v_w=8\text{m/s}$ :
  - Energy not delivered around 7,5% of potential energy
  - 150 MW wind-farm: 37 000 MWh not delivered -> 46 250 000 R/year
- Must be compared to annualized costs of required line upgrade





## Violation of Thermal Limits – Inter-trip



### More cost effective solution:

- Limitation of wind farm output only in situations in which one circuit is available (planned outage, unplanned outage)
- In case of minor overloads (below emergency rating):
  - Manual action of system operator
- In case of major overloads (above emergency rating):
  - Automatic inter-trip scheme





## Voltage Variations - Summary




- High voltages in case of  $\cos(\phi)=1$
- Small voltage variations if  $\cos(\phi)$  adjusted to actually generated power.
- Voltage control at wind farm connection point is possible but not required in this particular case.
- Voltage control must be seen as ancillary service that stabilizes the grid and secures the grid against voltage collapse in case of major disturbances.
- But: Typically voltage control capability of wind farms not available in case of zero power output ( $v_w < v_{w\_cutin}$ ).




## Impact on Short Circuit Currents



- DFIG:
  - Considerable contribution to peak short circuit current.
  - Contribution to thermal short circuit ratings: approx 1 p.u. shc-current
- WTG with fully rated converter:
  - Contribution to initial short circuit current: approx. 1 p.u. shc-current
  - Contribution to thermal short circuit ratings: approx 1 p.u. shc-current
- 150MW wind farm at Laingsburg:
  - Contribution to initial shc-current ( $I_{kss}$ ): approx 2 kA (at 132kV)
  - Contribution to peak shc-current ( $i_p$ ): 4,4 kA
  - Contribution to transient shc-current ( $I_{ks}$ ): 0,67 kA
- Contribution to fault levels not critical in this particular example because of low fault level at wind farm connection point.




## Impact on Flicker and Harmonics






- Analysis of Flicker and Harmonics using IEC 61400-21 data sheet of a typical variable-speed wind generator.
  - Flicker:  $P_{st} = 0,066$  /  $P_{lt} = 0,08$
  - Harmonics:  $THD = 0,75\%$
- Flicker generally low in case of large wind farms because Flicker-relevant turbulences within a wind farm are only weekly correlated
- Harmonics of modern wind turbines (with IGBT-converters) very low. Almost no harmonic current injections.

GTZ/ESKOM/DIGSILENT Presentation of results of feasibility studies for wind integration in the Western Cape 15





## Stage 2: Example for Wind Farm Integration into a Transmission Network







- ### Stage 2 – 750MW – Summary of Results
- No thermal overloads under n-1 conditions
  - Voltage variations very small, even in constant power factor operation.
  - Operation with constant Q (var-control) is appropriate. (Slow) voltage control is possible and should be considered.
  - 4x100Mvar shunt reactors required at Nuweweld substation (or equivalent var-absorption of the wind farms) because of proximity to Komsberg series compensation.
  - Series compensation at Komsberg should be resized for considering new line configuration.
  - With adjusted series compensation, shunt reactors at Nuweweld might not be required.
  - No power quality issues because of the large number of turbines and high fault level at the grid connection point
- GTZ/ESKOM/DIGSILENT Presentation of results of feasibility studies for wind integration in the Western Cape 20



---

**Stage 3: Feasibility Studies for the Integration of up to 2800MW of Wind Generation in the Western Cape into the ESKOM Transmission Grid**







---


**Stage 3 – 2800MW of Wind Generation in the Cape**

- Consideration of all wind farms in the Western Cape, for which application exist (2798MW by end of March 2009)
- High level feasibility studies considering the existing ESKOM transmission grid (excluding subtransmission,  $\leq 132\text{kV}$ )
- Constraints:
  - No major network upgrades (such as new lines)
  - Minor network upgrade, such as additional var-compensation is allowed.
- System 2009 (without the new 765kV line running into the Cape)

GTZ/ESKOM/DIGSILENT Presentation of results of feasibility studies for wind integration in the Western Cape 22







- ### Stage 3 – 2800MW in the Western Cape – Summary of Results
- Up to 1000MW of export from the Cape to the North under Low load – High Wind conditions.
  - No violation of thermal limits under n-1 conditions in all scenarios.
  - Voltages can be maintained within appropriate limits, without any additional reactive power compensation in the Western Cape.
  - The general feasibility of the integration of up to 2800MW of wind generation in the Western Cape, with regard to the impact on the transmission grid, could be demonstrated.
  - However:
    - Operation of the system with considerable export from the Cape to the North must be studied in further detail.
    - Size of Komsberg series compensation must be verified/redefined (see stage 2 studies)
    - More detailed studies are required for confirming these results.
- GTZ/ESKOM/DIGSILENT Presentation of results of feasibility studies for wind integration in the Western Cape
- 28



## Integration of Wind Energy into the Western Cape System - Summary



### Western Cape transmission system – excellent for wind integration:

- Cape system currently has an import problem (no export problem). Power import will be reduced during times of high wind generation.
- Large number of fast acting peak load units available that can be used for balancing wind variations.
- Pump storage can be used for supporting the balancing of wind variations.
- Some GTGs allow for SCO-operation – no need for additional dynamic reactive power compensation (SVC).

**At subtransmission levels ( $\leq 132\text{kV}$ ), transmission capacity will be limited in some cases.**



## What else needs to be done



- Additional, more detailed studies at transmission levels, including additional generation-load scenarios and alternative wind generation scenarios.
- Stability studies under various operating scenarios.
- Wind farm connection studies for every wind farm application.
- Studies related to transmission system operation under situations, in which the Cape exports power to the rest of the system
- Studies related to the expected total power variations of wind generation (variations, ramp-up and ramp-down speeds) for identifying additional reserve requirements have to be carried out.